

Prepared by: Twain Cacek

Checked by:

Calculation Title: Homer Harbor Navigation Improvements

Office: POA

Office:

Date: 8/22/2025

Date:

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

Earthquake moment magnitude, M_w

0.42 g

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-35.8 ft

-35.8 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

41.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ _{moist} (pcf)	γ _{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	15.0	7.5	0	CL	Clay	65.0	115.0	115.0	3.10	2.70	0.39	0.0	#N/A	#N/A	0.86	0.47	0.39		0.99	#N/A	#N/A		#N/A	0.590	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	7.00	-	#N/A	-
15.0	40.0	27.5	0	CL	Clay	65.0	115.0	115.0	5.40	3.95	1.45	0.0	#N/A	#N/A	3.16	1.72	1.45		0.92	#N/A	#N/A		#N/A	0.548	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	20.00	-	#N/A	-
40.0	44.0	42.0	10	CL	Clay	71.0	115.0	115.0	7.06	4.85	2.21	12.5	#N/A	#N/A	4.83	2.62	2.21		0.86	#N/A	#N/A		#N/A	0.510	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	14.50	-	#N/A	-
44.0	48.0	46.0	11	CL	Clay	71.0	115.0	115.0	7.52	5.10	2.42	13.8	#N/A	#N/A	5.29	2.87	2.42		0.84	#N/A	#N/A		#N/A	0.500	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	4.00	-	#N/A	-
48.0	54.0	51.0	14	CL	Clay	71.0	115.0	115.0	8.10	5.42	2.68	17.5	#N/A	#N/A	5.87	3.18	2.68		0.81	#N/A	#N/A		#N/A	0.486	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	5.00	-	#N/A	-
54.0	58.0	56.0	13	ML	Clay	57.0	120.0	120.0	8.69	5.73	2.96	16.3	#N/A	#N/A	6.45	3.49	2.96		0.79	#N/A	#N/A		#N/A	0.472	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	5.00	-	#N/A	-
58.0	61.0	59.5	17	ML	Clay	57.0	120.0	120.0	9.11	5.95	3.16	21.3	#N/A	#N/A	6.87	3.71	3.16		0.78	#N/A	#N/A		#N/A	0.461	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	3.50	-	#N/A	-
61.0	71.0	66.0	18	ML	Clay	57.0	120.0	120.0	9.89	6.35	3.53	22.5	#N/A	#N/A	7.65	4.12	3.53		0.75	#N/A	#N/A		#N/A	0.443	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	6.50	-	#N/A	-
71.0	80.0	75.5	7	SM		46.0	125.0	125.0	11.05	6.95	4.11	8.8	6.2	11.8	8.82	4.71	4.11		0.71	1.00	0.93		1.00	0.417	0.446	0.122	0.131	0.29	1.00E+00	0.388	9.50	3.689	0.034	0.321
80.0	90.0	85.0	24	SM		46.0	125.0	125.0	12.24	7.54	4.70	30.0	22.2	27.8	10.00	5.30	4.70		0.68	1.00	0.85		1.00	0.394	0.461	0.320	0.375	0.81	7.26E-01	0.052	9.50	0.493	0.011	0.106
90.0	94.0	92.0	35	SM		46.0	120.0	120.0	13.10	7.97	5.12	43.8	33.4	39.1	10.86	5.74	5.12		0.66	1.00	0.74		1.00	0.381	0.515	2.276	3.078	5.98	1.42E-49	0.000	7.00	0.000	0.000	0.000
94.0	100.0	97.0	55	SM		27.0	125.0	125.0	13.71	8.29	5.42	68.8	53.7	58.9	11.47	6.05	5.42		0.64	1.00	0.72		1.00	0.372	0.516	#####	#####	#####	0.00E+00	0.000	5.00	0.000	0.000	0.000
100.0	105.0	102.5	88	SM		27.0	125.0	125.0	14.40	8.63	5.77	110.0	84.5	89.7	12.16	6.40	5.77		0.63	1.00	0.70		1.00	0.364	0.517	#####	#####	#####	0.00E+00	0.000	5.50	0.000	0.000	0.000
105.0	111.0	108.0	100	SM		27.0	125.0	125.0	15.08	8.97	6.11	125.0	94.6	99.8	12.85	6.74	6.11		0.62	1.00	0.69		1.00	0.358	0.521	#####	#####	#####	0.00E+00	0.000	5.50	0.000	0.000	0.000

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max} /CSR to overcome uncertainty in r_d, especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$
Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$

4.182 ft

0.427 ft

Prepared by: Twain Cacek

Checked by:

Calculation Title: Homer Harbor Navigation Improvements

Office: POA

Office:

Date: 8/22/2025

Date:

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-10.4 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-10.4 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

16.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ _{moist} (pcf)	γ _{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	4.0	2.0	12	SP-SM		7.0	125.0	125.0	0.90	0.77	0.13	12.8	21.7	21.8	0.25	0.12	0.13		1.00	1.00	1.10		1.00	0.546	0.497	0.253	0.230	0.46	1.00E+00	0.129	1.50	0.194	0.021	0.032
4.0	8.0	6.0	23	SP-SM		7.0	125.0	125.0	1.40	1.02	0.38	27.3	43.9	44.0	0.75	0.37	0.38		0.99	1.00	1.10		1.00	0.541	0.492	#####	#####	39.89	1.05E-189	0.000	4.00	0.000	0.000	0.000
8.0	13.5	10.8	31	SP-SM		7.0	120.0	120.0	1.98	1.32	0.66	36.8	50.0	50.1	1.33	0.67	0.66		0.98	1.00	1.10		1.00	0.539	0.490	#####	#####	#####	0.00E+00	0.000	4.75	0.000	0.000	0.000
13.5	20.5	17.0	3	SM		45.0	125.0	125.0	2.75	1.71	1.04	3.8	5.5	11.1	2.10	1.06	1.04		0.96	1.00	1.07		1.00	0.530	0.496	0.134	0.126	0.25	1.00E+00	0.421	6.25	2.629	0.035	0.220
20.5	29.0	24.8	11	CL	Clay	72.0	115.0	115.0	3.68	2.19	1.48	13.8	#N/A	#N/A	3.03	1.54	1.48		0.93	#N/A	#N/A		#N/A	0.518	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	7.75	-	#N/A	-
29.0	35.0	32.0	2	CL	Clay	72.0	115.0	115.0	4.51	2.65	1.86	2.5	#N/A	#N/A	3.86	2.00	1.86		0.90	#N/A	#N/A		#N/A	0.509	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	7.25	-	#N/A	-
35.0	41.0	38.0	4	CL	Clay	85.0	115.0	115.0	5.20	3.02	2.18	5.0	#N/A	#N/A	4.55	2.37	2.18		0.87	#N/A	#N/A		#N/A	0.498	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	6.00	-	#N/A	-
41.0	47.5	44.3	3	CL	Clay	85.0	115.0	115.0	5.92	3.41	2.51	3.8	#N/A	#N/A	5.27	2.76	2.51		0.85	#N/A	#N/A		#N/A	0.485	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	6.25	-	#N/A	-
47.5	55.0	51.3	10	ML	Clay	70.0	120.0	120.0	6.74	3.85	2.89	12.5	#N/A	#N/A	6.09	3.20	2.89		0.81	#N/A	#N/A		#N/A	0.467	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	7.00	-	#N/A	-
55.0	58.0	56.5	13	SM		46.0	125.0	125.0	7.38	4.17	3.21	16.3	13.5	19.1	6.74	3.53	3.21		0.79	1.00	0.95		1.00	0.452	0.478	0.185	0.195	0.41	1.00E+00	0.176	5.25	0.924	0.024	0.126
58.0	62.0	60.0	8	SM		46.0	125.0	125.0	7.82	4.39	3.43	10.0	7.8	13.5	7.17	3.74	3.43		0.77	1.00	0.95		1.00	0.442	0.466	0.136	0.144	0.31	1.00E+00	0.325	3.50	1.137	0.031	0.108
62.0	68.0	65.0	9	SM		46.0	125.0	125.0	8.45	4.70	3.74	11.3	8.5	14.1	7.80	4.06	3.74		0.75	1.00	0.94		1.00	0.428	0.456	0.140	0.149	0.33	1.00E+00	0.304	5.00	1.518	0.030	0.150
68.0	76.0	72.0	32	SM		46.0	125.0	125.0	9.32	5.14	4.18	40.0	32.4	38.0	8.67	4.49	4.18		0.72	1.00	0.80		1.00	0.410	0.513	1.810	2.264	4.41	1.07E-35	0.000	7.00	0.000	0.000	0.000
76.0	83.0	79.5	100	SM		22.0	125.0	125.0	10.26	5.61	4.65	125.0	101.6	106.4	9.61	4.96	4.65		0.70	1.00	0.77		1.00	0.393	0.512	#####	#####	#####	0.00E+00	0.000	7.50	0.000	0.000	0.000
83.0	92.0	87.5	76	SM		22.0	125.0	125.0	11.26	6.11	5.15	95.0	75.2	79.9	10.61	5.46	5.15		0.67	1.00	0.74		1.00	0.377	0.511	#####	#####	#####	0.00E+00	0.000	8.00	0.000	0.000	0.000
92.0	98.1	95.1	100	SM		22.0	125.0	125.0	12.20	6.58	5.62	125.0	96.7	101.4	11.55	5.93	5.62		0.65	1.00	0.71		1.00	0.364	0.512	#####	#####	#####	0.00E+00	0.000	7.55	0.000	0.000	0.000

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max} /CSR to overcome uncertainty in r_d, especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$

6.402 ft

Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$

0.636 ft

Prepared by: Twain Cacek

Checked by:

Calculation Title: Homer Harbor Navigation Improvements

Office: POA

Office:

Date: 8/22/2025

Date:

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-16.0 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-16.0 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

◀ Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

21.0 ft (above the ground surface)

Sampler

Standard

◀ Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

◀ Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
▼ Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ_{moist} (pcf)	γ_{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ_{max}	ΔH (ft)	ΔLDI (ft)	ϵ_v	ΔS (ft)
				USCS Group Symbol	Flag				σ_v (ksf)	u (ksf)	σ'_v (ksf)				σ_v (ksf)	u (ksf)	σ'_v (ksf)	Flag						M _w , $\sigma'_{v, \alpha}$	M _w =7.5, σ'_v =1 atm, α =0	M _w , $\sigma'_{v, \alpha}$	M _w =7.5, σ'_v =1 atm, α =0							
0.0	8.0	4.0	1	SC		27.0	125.0	125.0	1.50	1.25	0.25	1.2	2.0	7.2	0.50	0.25	0.25		1.00	1.00	1.10		1.00	0.544	0.494	0.110	0.100	0.20	1.00E+00	0.500	3.50	1.750	0.044	0.156
8.0	17.0	12.5	1	CL	Clay	86.0	115.0	115.0	2.52	1.78	0.74	1.3	#N/A	#N/A	1.52	0.78	0.74		0.97	#N/A	#N/A		#N/A	0.546	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	8.50	-	#N/A	-
17.0	25.0	21.0	3	CL	Clay	86.0	115.0	115.0	3.50	2.31	1.19	3.8	#N/A	#N/A	2.50	1.31	1.19		0.94	#N/A	#N/A		#N/A	0.542	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	8.50	-	#N/A	-
25.0	40.0	32.5	2	CL	Clay	86.0	115.0	115.0	4.82	3.03	1.79	2.5	#N/A	#N/A	3.82	2.03	1.79		0.90	#N/A	#N/A		#N/A	0.522	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	11.50	-	#N/A	-
40.0	45.0	42.5	7	CL	Clay	86.0	115.0	115.0	5.97	3.65	2.32	8.8	#N/A	#N/A	4.97	2.65	2.32		0.85	#N/A	#N/A		#N/A	0.499	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	10.00	-	#N/A	-
45.0	51.0	48.0	3	CL	Clay	76.0	115.0	115.0	6.60	3.99	2.61	3.8	#N/A	#N/A	5.60	3.00	2.61		0.83	#N/A	#N/A		#N/A	0.486	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	5.50	-	#N/A	-
51.0	61.0	56.0	15	CL	Clay	76.0	115.0	115.0	7.52	4.49	3.03	18.8	#N/A	#N/A	6.52	3.49	3.03		0.79	#N/A	#N/A		#N/A	0.466	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	8.00	-	#N/A	-
61.0	72.0	66.5	25	ML	Clay	76.0	120.0	120.0	8.75	5.15	3.61	31.3	#N/A	#N/A	7.76	4.15	3.61		0.75	#N/A	#N/A		#N/A	0.438	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	10.50	-	#N/A	-
72.0	76.2	74.1	18	ML	Clay	59.0	120.0	120.0	9.67	5.62	4.04	22.5	#N/A	#N/A	8.67	4.62	4.04		0.72	#N/A	#N/A		#N/A	0.419	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	7.60	-	#N/A	-

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, $LDI = \Sigma(\Delta LDI)$

1.750 ft

Post-liquefaction reconsolidation settlement, $S = \Sigma(\Delta S)$

0.156 ft

Prepared by: Twain Cacek

Checked by:

Calculation Title: Homer Harbor Navigation Improvements

Office: POA

Office:

Date: 8/22/2025

Date:

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

Earthquake moment magnitude, M_w

0.42 g

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-10.4 ft

-10.4 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

5.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement

Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ _{moist} (pcf)	γ _{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	35.0	17.5	0	CL	Clay	84.0	115.0	115.0	2.66	1.74	0.92	0.0	#N/A	#N/A	2.01	1.09	0.92		0.96	#N/A	#N/A		#N/A	0.571	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	17.00	-	#N/A	-
35.0	43.0	39.0	7	CL	Clay	79.0	115.0	115.0	5.13	3.08	2.05	8.8	#N/A	#N/A	4.49	2.43	2.05		0.87	#N/A	#N/A		#N/A	0.519	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	21.50	-	#N/A	-
43.0	54.0	48.5	8	CL	Clay	79.0	115.0	115.0	6.23	3.68	2.55	10.0	#N/A	#N/A	5.58	3.03	2.55		0.83	#N/A	#N/A		#N/A	0.493	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	9.50	-	#N/A	-
54.0	64.0	59.0	10	CL	Clay	79.0	115.0	115.0	7.43	4.33	3.10	12.5	#N/A	#N/A	6.79	3.68	3.10		0.78	#N/A	#N/A		#N/A	0.465	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	10.50	-	#N/A	-
64.0	77.0	70.5	13	ML	Clay	70.0	120.0	120.0	8.79	5.05	3.74	16.3	#N/A	#N/A	8.14	4.40	3.74		0.73	#N/A	#N/A		#N/A	0.434	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	11.50	-	#N/A	-
77.0	84.0	80.5	26	ML	Clay	70.0	120.0	120.0	9.99	5.67	4.31	32.5	#N/A	#N/A	9.34	5.02	4.31		0.69	#N/A	#N/A		#N/A	0.409	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	10.00	-	#N/A	-
84.0	93.0	88.5	26	SM		46.0	125.0	125.0	10.97	6.17	4.79	32.5	24.1	29.7	10.32	5.52	4.79		0.67	1.00	0.84		1.00	0.392	0.469	0.391	0.468	1.00	1.62E-01	0.035	8.00	0.281	0.007	0.056
93.0	99.0	96.0	100	SM		46.0	125.0	125.0	11.90	6.64	5.26	125.0	98.4	104.0	11.25	5.99	5.26		0.65	1.00	0.73		1.00	0.378	0.517	#####	#####	#####	0.00E+00	0.000	7.50	0.000	0.000	0.000
99.0	103.0	101.0	86	SM		46.0	125.0	125.0	12.53	6.95	5.58	107.5	83.3	88.9	11.88	6.30	5.58		0.64	1.00	0.71		1.00	0.370	0.518	#####	#####	#####	0.00E+00	0.000	5.00	0.000	0.000	0.000

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max} /CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, $LDI = \Sigma(\Delta LDI)$
Post-liquefaction reconsolidation settlement, $S = \Sigma(\Delta S)$

0.281 ft

0.056 ft

Prepared by: Twain Cacek

Office: POA

Date: 4/11/2026

Checked by:

Office:

Date:

Calculation Title: Homer Harbor Navigation Improvements

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-7.4 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-7.4 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

5.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement

Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ_{moist} (pcf)	γ_{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	13.0	6.5	0	CL	Clay	70.0	115.0	115.0	1.21	0.87	0.34	0.0	#N/A	#N/A	0.75	0.41	0.34		0.99	#N/A	#N/A		#N/A	0.592	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	6.00	-	#N/A	-
13.0	28.5	20.8	0	CL	Clay	75.0	115.0	115.0	2.85	1.76	1.09	0.0	#N/A	#N/A	2.39	1.29	1.09		0.95	#N/A	#N/A		#N/A	0.564	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	14.25	-	#N/A	-
28.5	57.0	42.8	1	CL	Clay	72.0	115.0	115.0	5.38	3.13	2.25	1.3	#N/A	#N/A	4.92	2.67	2.25		0.85	#N/A	#N/A		#N/A	0.508	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	22.00	-	#N/A	-
57.0	78.5	67.8	3	CL	Clay	80.0	115.0	115.0	8.25	4.69	3.56	3.8	#N/A	#N/A	7.79	4.23	3.56		0.74	#N/A	#N/A		#N/A	0.442	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	25.00	-	#N/A	-
78.5	82.0	80.3	6	ML	Clay	67.0	120.0	120.0	9.72	5.47	4.25	7.5	#N/A	#N/A	9.26	5.01	4.25		0.69	#N/A	#N/A		#N/A	0.412	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	12.50	-	#N/A	-

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$

0.000 ft

Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$

0.000 ft

Prepared by: Twain Cacek

Office: POA

Date: 4/11/2026

Checked by:

Office:

Date:

Calculation Title: Homer Harbor Navigation Improvements

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-9.5 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-9.5 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

5.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement

Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ _{moist} (pcf)	γ _{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	18.0	9.0	0	CL	Clay	51.0	115.0	115.0	1.63	1.15	0.47	0.0	#N/A	#N/A	1.04	0.56	0.47		0.98	#N/A	#N/A		#N/A	0.588	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	8.50	-	#N/A	-
18.0	42.0	30.0	2	CL	Clay	79.0	115.0	115.0	4.04	2.46	1.58	2.5	#N/A	#N/A	3.45	1.87	1.58		0.91	#N/A	#N/A		#N/A	0.542	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	21.00	-	#N/A	-
42.0	69.0	55.5	4	ML	Clay	58.0	120.0	115.0	6.98	4.06	2.92	5.0	#N/A	#N/A	6.38	3.46	2.92		0.79	#N/A	#N/A		#N/A	0.474	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	25.50	-	#N/A	-
69.0	81.0	75.0	7	CL	Clay	80.0	115.0	115.0	9.22	5.27	3.95	8.8	#N/A	#N/A	8.63	4.68	3.95		0.71	#N/A	#N/A		#N/A	0.425	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	19.50	-	#N/A	-

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$ 0.000 ft
Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$ 0.000 ft

Prepared by: Twain Cacek

Office: POA

Date: 4/11/2026

Checked by:

Office:

Date:

Calculation Title: Homer Harbor Navigation Improvements

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-10.8 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-10.8 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

5.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement

Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ _{moist} (pcf)	γ _{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	10.5	5.3	0	SP-SM		6.0	120.0	110.0	1.25	1.00	0.25	0.0	#####	#N/A	0.58	0.33	0.25		0.99	#N/A	#N/A		1.00	0.627	#N/A	0.000	#N/A	0.00	#VALUE!	#N/A	4.75	-	#N/A	-
10.5	60.0	35.3	1	CL	Clay	84.0	115.0	115.0	4.63	2.87	1.75	1.3	#N/A	#N/A	3.95	2.20	1.75		0.89	#N/A	#N/A		#N/A	0.545	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	30.00	-	#N/A	-
60.0	76.0	68.0	2	ML	Clay	75.0	120.0	115.0	8.39	4.92	3.48	2.5	#N/A	#N/A	7.72	4.24	3.48		0.74	#N/A	#N/A		#N/A	0.449	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	32.75	-	#N/A	-
76.0	80.0	78.0	7	SM		25.0	120.0	115.0	9.54	5.54	4.00	8.8	6.3	11.3	8.87	4.87	4.00		0.70	1.00	0.94		1.00	0.425	0.453	0.120	0.128	0.28	1.00E+00	0.409	10.00	4.089	0.035	0.346

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$

4.089 ft

Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$

0.346 ft

Prepared by: Twain Cacek

Office: POA

Date: 4/11/2026

Checked by:

Office:

Date:

Calculation Title: Homer Harbor Navigation Improvements

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-17.3 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-17.3 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

5.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement

Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ_{moist} (pcf)	γ_{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	25.0	12.5	1	ML	Clay	84.0	120.0	115.0	2.52	1.86	0.66	1.1	#N/A	#N/A	1.44	0.78	0.66		0.97	#N/A	#N/A		#N/A	0.581	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	12.00	-	#N/A	-
25.0	47.0	36.0	2	CL	Clay	74.0	115.0	115.0	5.22	3.33	1.89	2.5	#N/A	#N/A	4.14	2.25	1.89		0.88	#N/A	#N/A		#N/A	0.527	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	23.50	-	#N/A	-
47.0	66.0	56.5	7	CL	Clay	66.0	115.0	115.0	7.58	4.61	2.97	8.8	#N/A	#N/A	6.50	3.53	2.97		0.79	#N/A	#N/A		#N/A	0.471	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	20.50	-	#N/A	-
66.0	78.0	72.0	10	CL	Clay	80.0	115.0	115.0	9.36	5.57	3.79	12.5	#N/A	#N/A	8.28	4.49	3.79		0.72	#N/A	#N/A		#N/A	0.432	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	15.50	-	#N/A	-
64.0	78.0	71.0	10	ML	Clay	70.0	120.0	120.0	9.24	5.51	3.73	12.5	#N/A	#N/A	8.16	4.43	3.73		0.73	#N/A	#N/A		#N/A	0.435	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	-1.00	-	#N/A	-
78.0	81.5	79.8	13	SM		25.0	120.0	120.0	10.29	6.06	4.24	16.3	11.7	16.8	9.21	4.98	4.24		0.70	1.00	0.92		1.00	0.413	0.450	0.158	0.172	0.38	1.00E+00	0.226	8.75	1.980	0.026	0.231

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$ 1.980 ft
Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$ 0.231 ft

Prepared by: Twain Cacek

Checked by:

Calculation Title: Homer Harbor Navigation Improvements

Office: POA

Office:

Date: 4/11/2026

Date:

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42 g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-15.6 ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-15.6 ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

Use drop-down list.

Energy ratio, ER

75 percent

Borehole diameter

4.000 in

Rod stickup

5.0 ft (above the ground surface)

Sampler

Standard

Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangent

H:1V

Note: Leave blank if level ground ($\beta = 0^\circ$).

Slope angle, β

0.0 deg

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement

Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ_{moist} (pcf)	γ_{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	18.0	9.0	0	ML	Clay	86.0	120.0	115.0	2.01	1.54	0.47	0.0	#N/A	#N/A	1.04	0.56	0.47		0.98	#N/A	#N/A		#N/A	0.588	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	8.50	-	#N/A	-
18.0	58.0	38.0	1	CL	Clay	75.0	115.0	115.0	5.34	3.34	2.00	1.3	#N/A	#N/A	4.37	2.37	2.00		0.87	#N/A	#N/A		#N/A	0.521	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	29.00	-	#N/A	-
58.0	78.0	68.0	4	ML	Clay	75.0	120.0	115.0	8.79	5.22	3.58	5.0	#N/A	#N/A	7.82	4.24	3.58		0.74	#N/A	#N/A		#N/A	0.442	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	30.00	-	#N/A	-
78.0	81.5	79.8	1	ML	Clay	54.0	120.0	115.0	10.14	5.95	4.19	1.3	#N/A	#N/A	9.17	4.98	4.19		0.70	#N/A	#N/A		#N/A	0.415	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	11.75	-	#N/A	-

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, LDI = $\Sigma(\Delta LDI)$

0.000 ft

Post-liquefaction reconsolidation settlement, S = $\Sigma(\Delta S)$

0.000 ft

Prepared by: Twain Cacek

Checked by:

Calculation Title: Homer Harbor Navigation Improvements

Office: POA

Office:

Date: 4/11/2026

Date:

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
Boulanger et al. SPT-based Methodology

Earthquake

Maximum horizontal ground surface acceleration, a_{max}

0.42

g

Earthquake moment magnitude, M_w

7.5

Ground Water Conditions

Coincident water level (depth) at time of SPT, $h_{w,SPT}$

-11.2

ft

Coincident water level (depth) at time of earthquake, $h_{w,EQ}$

-11.2

ft

Note: Use a negative value for a water level above the ground surface and a positive value for ground water.

SPT Equipment

Equipment

Automatic-Trip Hammer

◀ Use drop-down list.

Energy ratio, ER

75

percent

Borehole diameter

4.000

in

Rod stickup

5.0

ft (above the ground surface)

Sampler

Standard

◀ Use drop-down list.

Standard split-spoon sampler without room for liners (the inside diameter is a constant 1.375 inch)

Particle-Size Data

Predominant grain type

Quartz

◀ Use drop-down list.

Empirical constant, Q

10

Ground Surface Geometry

Slope cotangentH:1V

Slope angle, β

0.0

deg

Note: Leave blank if level ground ($\beta = 0^\circ$).

Liquefaction Triggering, Lateral Spreading Deformation, and Post-Liquefaction Reconsolidation Settlement
▼ Use drop-down list.

Z _{top} (ft)	Z _{bot} (ft)	Z _{avg} (ft)	N _m (bpf)	Soil Type		FC (%)	γ _{moist} (pcf)	γ _{sat} (pcf)	Time of SPT			N ₆₀ (bpf)	N _{1,60} (bpf)	N _{1,60cs} (bpf)	During Earthquake				r _d	MSF	K _σ	K _o	K _α	CSR		CRR		FS _L	P _L	γ _{max}	ΔH (ft)	ΔLDI (ft)	ε _v	ΔS (ft)
				USCS Group Symbol	Flag				σ _v (ksf)	u (ksf)	σ' _v (ksf)				σ _v (ksf)	u (ksf)	σ' _v (ksf)	Flag						M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0	M _w ,σ' _v ,α	M _w =7.5, σ' _v =1 atm, α=0							
0.0	18.0	9.0	0	ML	Clay	62.0	120.0	115.0	1.73	1.26	0.47	0.0	#N/A	#N/A	1.04	0.56	0.47		0.98	#N/A	#N/A		#N/A	0.588	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	8.50	-	#N/A	-
18.0	42.0	30.0	1	CL	Clay	88.0	115.0	115.0	4.15	2.57	1.58	1.3	#N/A	#N/A	3.45	1.87	1.58		0.91	#N/A	#N/A		#N/A	0.542	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	21.00	-	#N/A	-
42.0	82.0	62.0	3	ML	Clay	79.0	120.0	115.0	7.83	4.57	3.26	3.8	#N/A	#N/A	7.13	3.87	3.26		0.77	#N/A	#N/A		#N/A	0.457	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	32.00	-	#N/A	-

Notes: Depth, z, is between second and third SPT 6-inch intervals.
Use Shake2000 or Quake/W to compute τ_{max}/CSR to overcome uncertainty in r_d , especially at greater depth which is typical for a dam.

Lateral spreading displacement, $LDI = \Sigma(\Delta LDI)$

0.000

ft

Post-liquefaction reconsolidation settlement, $S = \Sigma(\Delta S)$

0.000

ft